

Capital Region Environmental Laboratory137 Columbia Turnpike, Rensselaer, NY 12144
(518) 949-2020**Needham Risk Management Resource Group**1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033**Printed On** 7/11/2025

Page 1 of 1

Sample ID: BG05952**Date Received:** 06/04/2025**Time Received:** 12:30**Date Finalized:** 7/11/2025**PO Number:****Your Ref:** Menands**Customer:** Needham Risk Management Resource Group**Owner:** Menands UFSD**Sample Loc:** MS-1-WC-7-P1**Sample Pt:** Bottle Fill Near Gym First Draw**Collect Date:** 06/04/2025**Collect Time:** 00:00**Collected by:****Receipt Temp:** 27 C See note 1**Water Source:****Chlorinated:** No **Field Residual Chlorine:****Potable:** Yes**Grab/Comp:** Grab**L a b o r a t o r y R e p o r t**

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|----------------|--------|-----|------------|-------|-------------|---------|---------------|
| Lead (schools) | <1.0 | 15 | | ug/L | SM 22 3113B | MN | 7/9/2025 |

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020**Reviewed by Brian Collins**

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 7/11/2025

Page 1 of 1

Sample ID: BG05953
Date Received: 06/04/2025
Time Received: 12:30
Date Finalized: 7/11/2025
PO Number:
Your Ref: MenandsCustomer: Needham Risk Management Resource Group
Owner: Menands UFSD
Sample Loc: MS-1-WC-7-F1
Sample Pt: Bottle Fill Near Gym FlushCollect Date: 06/04/2025
Collect Time: 00:00
Collected by:
Receipt Temp: 27 C See note 1Water Source:
Chlorinated: No Field Residual Chlorine:Potable: Yes
Grab/Comp: Grab

Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|----------------|--------|-----|------------|-------|-------------|---------|---------------|
| Lead (schools) | <1.0 | 15 | | ug/L | SM 22 3113B | MN | 7/9/2025 |

Qualifiers Key:

| | | | | | |
|--------|--|--------|---|---|---------------------------|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| C(+/-) | CCV outside acceptance limits | Z | Analysis is not state-certified | G | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | P | Sample preserved at lab |
| J | Analyte detected below quantitation limit | I(+/-) | IS/Surrogate outside acceptance limits | | |

(+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Capital Region Environmental Laboratory137 Columbia Turnpike, Rensselaer, NY 12144
(518) 949-2020**Needham Risk Management Resource Group**1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033**Printed On** 7/11/2025 Page 1 of 1**Sample ID:** BG05955
Date Received: 06/04/2025
Time Received: 12:30
Date Finalized: 7/11/2025
PO Number:
Your Ref: Menands**Customer:** Needham Risk Management Resource Group
Owner: Menands UFSD
Sample Loc: MS-1-WC-8-P1
Sample Pt: Water Fountainl Near Gym First Draw**Collect Date:** 06/04/2025
Collect Time: 00:00
Collected by:
Receipt Temp: 27 C See note 1**Water Source:**
Chlorinated: No **Field Residual Chlorine:****Potable:** Yes
Grab/Comp: Grab**L a b o r a t o r y R e p o r t**

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|----------------|--------|-----|------------|-------|-------------|---------|---------------|
| Lead (schools) | <1.0 | 15 | | ug/L | SM 22 3113B | MN | 7/9/2025 |

Qualifiers Key:

| | | | | | |
|--------|--|--------|---|---|---------------------------|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| C(+/-) | CCV outside acceptance limits | Z | Analysis is not state-certified | G | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | P | Sample preserved at lab |
| J | Analyte detected below quantitation limit | I(+/-) | IS/Surrogate outside acceptance limits | | |

(+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020**Reviewed by Brian Collins**
These results relate to samples as received.**New York State DOH E.L.A.P. # 10350****MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.