

Needham Risk Management Resource Group
1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025 Page 1 of 1

Sample ID: BG04857
Date Received: 05/15/2025
Time Received: 09:15
Date Finalized: 5/29/2025
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Menands
Sample Loc: MS-0-WC-1
Sample Pt: Bottle fill across B02

Collect Date: 05/15/2025
Collect Time: 04:58
Collected by: NEEDHAM
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
C(+/-) CCV outside acceptance limits	Z Analysis is not state-certified	G Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	P Sample preserved at lab
J Analyte detected below quantitation limit	I(+/-) IS/Surrogate outside acceptance limits	

(+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04858

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-0-WC-2

Sample Pt: Water fountain across B02

Collect Date: 05/15/2025

Collect Time: 04:58

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04859

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-WC-3

Sample Pt: Bottle fill grade 2-4 hallway

Collect Date: 05/15/2025

Collect Time: 05:03

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04860

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-WC-4

Sample Pt: Water fountain grade 2-4 hallway

Collect Date: 05/15/2025

Collect Time: 05:03

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins

These results relate to samples as received.

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025 Page 1 of 1

Sample ID: BG04861
Date Received: 05/15/2025
Time Received: 09:15
Date Finalized: 5/29/2025
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Menands
Sample Loc: MS-1-CF-5
Sample Pt: Room 125 Sink

Collect Date: 05/15/2025
Collect Time: 05:05
Collected by: NEEDHAM
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04862

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-KF-6

Sample Pt: Single bay island sink

Collect Date: 05/15/2025

Collect Time: 05:07

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025 Page 1 of 1

Sample ID: BG04863
Date Received: 05/15/2025
Time Received: 09:15
Date Finalized: 5/29/2025
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Menands
Sample Loc: MS-1-WC-7
Sample Pt: Bottle fill next gym

Collect Date: 05/15/2025
Collect Time: 05:11
Collected by: NEEDHAM
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	29.6	15	X	ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04864

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-WC-8

Sample Pt: Water fountain next gym

Collect Date: 05/15/2025

Collect Time: 05:11

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04865

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-9

Sample Pt: RM 157 Sink

Collect Date: 05/15/2025

Collect Time: 05:14

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins

These results relate to samples as received.

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04866

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-WC-10

Sample Pt: Bottle fill across 162

Collect Date: 05/15/2025

Collect Time: 05:15

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04867

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-WC-11

Sample Pt: Water fountain across 162

Collect Date: 05/15/2025

Collect Time: 05:15

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04868

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-12

Sample Pt: RM 162 Sink

Collect Date: 05/15/2025

Collect Time: 05:16

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	3.5	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04869

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-KF-13

Sample Pt: RM 172 Faculty

Collect Date: 05/15/2025

Collect Time: 05:17

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04870

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-14

Sample Pt: RM 164 Sink

Collect Date: 05/15/2025

Collect Time: 05:18

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.1	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins

These results relate to samples as received.

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04871

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-DW-15

Sample Pt: RM 166 Water fountain

Collect Date: 05/15/2025

Collect Time: 05:20

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.2	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04872

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-16

Sample Pt: RM 166 Sink

Collect Date: 05/15/2025

Collect Time: 05:21

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.6	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins

These results relate to samples as received.

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04873

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-DW-17

Sample Pt: RM 168 Water fountain

Collect Date: 05/15/2025

Collect Time: 05:22

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.6	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04874

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-18

Sample Pt: RM 168 Sink

Collect Date: 05/15/2025

Collect Time: 05:23

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	3.3	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04876

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-20

Sample Pt: RM 169 left sink

Collect Date: 05/15/2025

Collect Time: 05:26

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04877

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-NS-21

Sample Pt: Nurses Sink

Collect Date: 05/15/2025

Collect Time: 05:35

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

C(+/-) CCV outside acceptance limits

S(+/-) Lab control sample outside acceptance limits

J Analyte detected below quantitation limit

(+ Result may be biased high / - Result may be biased low)

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

I(+/-) IS/Surrogate outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

G Incorrect bottle received

P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025 Page 1 of 1

Sample ID: BG04878

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-22

Sample Pt: RM 150 left sink

Collect Date: 05/15/2025

Collect Time: 05:38

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road

STE 102

Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04879

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-CF-23

Sample Pt: RM 150 right sink

Collect Date: 05/15/2025

Collect Time: 05:38

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins

Lead Technical Director Environmental Laboratory
and contact person

If you have questions, please call.

(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins

These results relate to samples as received.

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04880

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Menands
Sample Loc: MS-1-KF-24
Sample Pt: 2 bay sink left

Collect Date: 05/15/2025

Collect Time: 05:41

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

1955 Ferndale Road
STE 102
Castleton-on-Hudson, NY 12033

Printed On 5/29/2025

Page 1 of 1

Sample ID: BG04881

Date Received: 05/15/2025

Time Received: 09:15

Date Finalized: 5/29/2025

PO Number:

Your Ref:

Customer: Needham Risk Management Resource Group

Owner: Menands

Sample Loc: MS-1-KF-25

Sample Pt: 2 bay sink right

Collect Date: 05/15/2025

Collect Time: 05:41

Collected by: NEEDHAM

Receipt Temp: 21 C See Note 1

Water Source:

Chlorinated: No Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.7	15		ug/L		MN	5/28/2025

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins

These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.