

December 09, 2020

John Tranter
Intertek PSI
104 Erie Boulevard
Suite 1
Schenectady, NY 12305

RE: Project: MENANDS CSD 11/21
Pace Project No.: 70154911

Dear John Tranter:

Enclosed are the analytical results for sample(s) received by the laboratory on November 25, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: FACULTY ROOM 172		Lab ID: 70154911001	Collected: 11/21/20 07:15	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 170		Lab ID: 70154911002	Collected: 11/21/20 07:19	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		12/08/20 16:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 170 BATHROOM		Lab ID: 70154911003	Collected: 11/21/20 07:21	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 164		Lab ID: 70154911004	Collected: 11/21/20 07:28	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		12/08/20 16:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 164 BATHROOM		Lab ID: 70154911005	Collected: 11/21/20 07:32	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 162		Lab ID: 70154911006	Collected: 11/21/20 07:40	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.2	ug/L	1.0	1		12/08/20 16:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 162 BATHROOM		Lab ID: 70154911007	Collected: 11/21/20 07:43	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		12/08/20 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 168 WATER FOUNTAIN		Lab ID: 70154911008	Collected: 11/21/20 07:50	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/08/20 16:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 168		Lab ID: 70154911009	Collected: 11/21/20 07:53	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.6	ug/L	1.0	1		12/08/20 16:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 168 BATHROOM		Lab ID: 70154911010		Collected: 11/21/20 07:55		Received: 11/25/20 10:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		12/08/20 16:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 169 WATER FOUNTAIN		Lab ID: 70154911011	Collected: 11/21/20 08:03	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 169 LEFT		Lab ID: 70154911012	Collected: 11/21/20 08:05	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 169 RIGHT		Lab ID: 70154911013	Collected: 11/21/20 08:08	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 169 BATHROOM		Lab ID: 70154911014	Collected: 11/21/20 08:10	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 16:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 166		Lab ID: 70154911015	Collected: 11/21/20 08:18	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.4	ug/L	1.0	1		12/08/20 17:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 166 BATHROOM		Lab ID: 70154911016		Collected: 11/21/20 08:20		Received: 11/25/20 10:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	10.8	ug/L	1.0	1		12/08/20 17:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 166		Lab ID: 70154911017	Collected: 11/21/20 08:22	Received: 11/25/20 10:50	Matrix: Drinking Water			
WATERFOUNTAIN								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/08/20 17:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 107 HEALTH OFFICE SINK		Lab ID: 70154911018	Collected: 11/21/20 08:34	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 107 HEALTH OFFICE BR		Lab ID: 70154911019	Collected: 11/21/20 08:35	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 157		Lab ID: 70154911020	Collected: 11/21/20 08:44	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM MAIN LOBBY RIGH		Lab ID: 70154911021	Collected: 11/21/20 08:55	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.6	ug/L	1.0	1		12/08/20 17:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM MAIN LOBBY LEFT		Lab ID: 70154911022	Collected: 11/21/20 08:56	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM MAIN LOBBY RIGHT		Lab ID: 70154911023	Collected: 11/21/20 09:00	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	26.7	ug/L	1.0	1		12/08/20 17:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM MAIN LOBBY MIDDLE		Lab ID: 70154911024	Collected: 11/21/20 09:01	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		12/08/20 17:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM MAIN LOBBY LEFT		Lab ID: 70154911025	Collected: 11/21/20 09:02	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 150 1 UPPER		Lab ID: 70154911026	Collected: 11/21/20 09:20	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/08/20 17:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 150 2 LOWER		Lab ID: 70154911027	Collected: 11/21/20 09:21	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: ROOM 146 OFFICE BATHROOM		Lab ID: 70154911028	Collected: 11/21/20 09:30	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		12/08/20 17:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: LOCKER ROOM 143		Lab ID: 70154911029	Collected: 11/21/20 09:44	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/08/20 17:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: LOCKER ROOM 142		Lab ID: 70154911030	Collected: 11/21/20 09:40	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/08/20 17:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: KITCHEN (LEFT OF DISHWASHER)		Lab ID: 70154911031	Collected: 11/21/20 09:55	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/08/20 17:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: KITCHEN BACK DOUBLE SINK 1 LEF		Lab ID: 70154911032	Collected: 11/21/20 09:58	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 17:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: KITCHEN BACK DOUBLE SINK 2 RIG		Lab ID: 70154911033	Collected: 11/21/20 09:59	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/08/20 17:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: HANDICAP BATHROOM BY KITCHEN		Lab ID: 70154911034	Collected: 11/21/20 10:06	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		12/08/20 17:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM BY 125 RIGHT		Lab ID: 70154911035	Collected: 11/21/20 10:12	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.0	ug/L	1.0	1		12/08/20 17:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM BY 125 **Lab ID:** 70154911036 **Collected:** 11/21/20 10:10 **Received:** 11/25/20 10:50 **Matrix:** Drinking Water
LEFT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/08/20 17:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM BY 125 **Lab ID:** 70154911037 **Collected:** 11/21/20 10:21 **Received:** 11/25/20 10:50 **Matrix:** Drinking Water
RIGHT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		12/08/20 17:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM BY 125 MIDDLE		Lab ID: 70154911038	Collected: 11/21/20 10:19	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM BY 125 **Lab ID:** 70154911039 **Collected:** 11/21/20 10:17 **Received:** 11/25/20 10:50 **Matrix:** Drinking Water
LEFT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		12/08/20 18:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: WATERFOUNTAIN BY 125		Lab ID: 70154911040	Collected: 11/21/20 10:23	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: WATERFOUNTAIN MAIN LOBBY		Lab ID: 70154911041	Collected: 11/21/20 10:34	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM BY B02 **Lab ID:** 70154911042 Collected: 11/21/20 10:46 Received: 11/25/20 10:50 Matrix: Drinking Water
LEFT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: BOYS BATHROOM BY B02 **Lab ID:** 70154911043 **Collected:** 11/21/20 10:47 **Received:** 11/25/20 10:50 **Matrix:** Drinking Water
RIGHT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/08/20 18:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: WATEROFUNTAIN BY B02		Lab ID: 70154911044	Collected: 11/21/20 10:53	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: WATERFOUNTAIN ACROSS 162		Lab ID: 70154911045	Collected: 11/21/20 11:04	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: GIRLS BATHROOM BY B02 **Lab ID:** 70154911046 **Collected:** 11/21/20 10:50 **Received:** 11/25/20 10:50 **Matrix:** Drinking Water
LEFT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/08/20 18:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: #50 WATERFOUNTAIN BY 125 BUBBL		Lab ID: 70154911047	Collected: 11/21/20 10:30	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: #51 WATERFOUNTAIN MAIN LOBBY B		Lab ID: 70154911048	Collected: 11/21/20 10:36	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: #52 WATEROFUNTAIN BY B02 BUBBL		Lab ID: 70154911049	Collected: 11/21/20 10:54	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Sample: #53 WATEROFUNTAIN BY 162 BUBBL		Lab ID: 70154911050	Collected: 11/21/20 11:06	Received: 11/25/20 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/08/20 18:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

QC Batch: 188639

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70154911001, 70154911002, 70154911003

METHOD BLANK: 925656

Matrix: Water

Associated Lab Samples: 70154911001, 70154911002, 70154911003

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/20 15:41	

LABORATORY CONTROL SAMPLE: 925657

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.4	105	85-115	

MATRIX SPIKE SAMPLE: 925660

Parameter	Units	70155096001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.0	4	5.9	122	70-130	

MATRIX SPIKE SAMPLE: 925662

Parameter	Units	70155211003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.4	4	6.9	112	70-130	

SAMPLE DUPLICATE: 925659

Parameter	Units	70155096001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.0	<1.0		

SAMPLE DUPLICATE: 925661

Parameter	Units	70155211003 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.4	2.4	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: MENANDS CSD 11/21
Pace Project No.: 70154911

QC Batch:	188641	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154911004, 70154911005, 70154911006, 70154911007, 70154911008, 70154911009, 70154911010, 70154911011, 70154911012, 70154911013, 70154911014, 70154911015, 70154911016, 70154911017, 70154911018, 70154911019, 70154911020, 70154911021, 70154911022, 70154911023		

METHOD BLANK:	925663	Matrix:	Water
Associated Lab Samples:	70154911004, 70154911005, 70154911006, 70154911007, 70154911008, 70154911009, 70154911010, 70154911011, 70154911012, 70154911013, 70154911014, 70154911015, 70154911016, 70154911017, 70154911018, 70154911019, 70154911020, 70154911021, 70154911022, 70154911023		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/20 16:31	

LABORATORY CONTROL SAMPLE:	925664					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.2	104	85-115	

MATRIX SPIKE SAMPLE:		925666					
		70154911004	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	4.0	4	8.6	115	70-130	

MATRIX SPIKE SAMPLE:		925668					
		70154911014	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	5.3	111	70-130	

SAMPLE DUPLICATE:	925665				
Parameter	Units	70154911004 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.0	4.0	0	

SAMPLE DUPLICATE:	925667				
Parameter	Units	70154911014 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: MENANDS CSD 11/21
Pace Project No.: 70154911

QC Batch:	188642	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154911024, 70154911025, 70154911026, 70154911027, 70154911028, 70154911029, 70154911030, 70154911031, 70154911032, 70154911033, 70154911034, 70154911035, 70154911036, 70154911037, 70154911038, 70154911039, 70154911040, 70154911041, 70154911042, 70154911043		

METHOD BLANK:	925669	Matrix:	Water
Associated Lab Samples:	70154911024, 70154911025, 70154911026, 70154911027, 70154911028, 70154911029, 70154911030, 70154911031, 70154911032, 70154911033, 70154911034, 70154911035, 70154911036, 70154911037, 70154911038, 70154911039, 70154911040, 70154911041, 70154911042, 70154911043		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/20 17:22	

LABORATORY CONTROL SAMPLE:	925670					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.1	104	85-115	

MATRIX SPIKE SAMPLE:		925672					
		70154911024	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.5	4	6.9	110	70-130	

MATRIX SPIKE SAMPLE:		925674					
		70154911034	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.3	4	6.8	114	70-130	

SAMPLE DUPLICATE: 925671					
Parameter	Units	70154911024 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.5	2.4	2	

SAMPLE DUPLICATE: 925673

Parameter	Units	70154911034 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.3	2.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: MENANDS CSD 11/21
Pace Project No.: 70154911

QC Batch:	188644	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70154911044, 70154911045, 70154911046, 70154911047, 70154911048, 70154911049, 70154911050

METHOD BLANK: 925676 Matrix: Water
Associated Lab Samples: 70154911044, 70154911045, 70154911046, 70154911047, 70154911048, 70154911049, 70154911050

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/20 18:10	

LABORATORY CONTROL SAMPLE: 925677

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.6	105	85-115	

MATRIX SPIKE SAMPLE: 925679

Parameter	Units	70154911044 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.6	113	70-130	

MATRIX SPIKE SAMPLE: 925681

Parameter	Units	70154981019 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.4	4	8.5	110	70-130	

SAMPLE DUPLICATE: 925678

Parameter	Units	70154911044 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 925680

Parameter	Units	70154981019 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.4	4.1	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70154911001	FACULTY ROOM 172	EPA 200.8	188639		
70154911002	ROOM 170	EPA 200.8	188639		
70154911003	ROOM 170 BATHROOM	EPA 200.8	188639		
70154911004	ROOM 164	EPA 200.8	188641		
70154911005	ROOM 164 BATHROOM	EPA 200.8	188641		
70154911006	ROOM 162	EPA 200.8	188641		
70154911007	ROOM 162 BATHROOM	EPA 200.8	188641		
70154911008	ROOM 168 WATER FOUNTAIN	EPA 200.8	188641		
70154911009	ROOM 168	EPA 200.8	188641		
70154911010	ROOM 168 BATHROOM	EPA 200.8	188641		
70154911011	ROOM 169 WATER FOUNTAIN	EPA 200.8	188641		
70154911012	ROOM 169 LEFT	EPA 200.8	188641		
70154911013	ROOM 169 RIGHT	EPA 200.8	188641		
70154911014	ROOM 169 BATHROOM	EPA 200.8	188641		
70154911015	ROOM 166	EPA 200.8	188641		
70154911016	ROOM 166 BATHROOM	EPA 200.8	188641		
70154911017	ROOM 166 WATERFOUNTAIN	EPA 200.8	188641		
70154911018	ROOM 107 HEALTH OFFICE SINK	EPA 200.8	188641		
70154911019	ROOM 107 HEALTH OFFICE BR	EPA 200.8	188641		
70154911020	ROOM 157	EPA 200.8	188641		
70154911021	GIRLS BATHROOM MAIN LOBBY RIGH	EPA 200.8	188641		
70154911022	GIRLS BATHROOM MAIN LOBBY LEFT	EPA 200.8	188641		
70154911023	BOYS BATHROOM MAIN LOBBY RIGHT	EPA 200.8	188641		
70154911024	BOYS BATHROOM MAIN LOBBY MIDDLE	EPA 200.8	188642		
70154911025	BOYS BATHROOM MAIN LOBBY LEFT	EPA 200.8	188642		
70154911026	ROOM 150 1 UPPER	EPA 200.8	188642		
70154911027	ROOM 150 2 LOWER	EPA 200.8	188642		
70154911028	ROOM 146 OFFICE BATHROOM	EPA 200.8	188642		
70154911029	LOCKER ROOM 143	EPA 200.8	188642		
70154911030	LOCKER ROOM 142	EPA 200.8	188642		
70154911031	KITCHEN (LEFT OF DISHWASHER)	EPA 200.8	188642		
70154911032	KITCHEN BACK DOUBLE SINK 1 LEFT	EPA 200.8	188642		
70154911033	KITCHEN BACK DOUBLE SINK 2 RIGHT	EPA 200.8	188642		
70154911034	HANDICAP BATHROOM BY KITCHEN	EPA 200.8	188642		
70154911035	BOYS BATHROOM BY 125 RIGHT	EPA 200.8	188642		
70154911036	BOYS BATHROOM BY 125 LEFT	EPA 200.8	188642		
70154911037	GIRLS BATHROOM BY 125 RIGHT	EPA 200.8	188642		
70154911038	GIRLS BATHROOM BY 125 MIDDLE	EPA 200.8	188642		
70154911039	GIRLS BATHROOM BY 125 LEFT	EPA 200.8	188642		
70154911040	WATERFOUNTAIN BY 125	EPA 200.8	188642		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: MENANDS CSD 11/21

Pace Project No.: 70154911

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70154911041	WATERFOUNTAIN MAIN LOBBY	EPA 200.8	188642		
70154911042	BOYS BATHROOM BY B02 LEFT	EPA 200.8	188642		
70154911043	BOYS BATHROOM BY B02 RIGHT	EPA 200.8	188642		
70154911044	WATEROFUNTAIN BY B02	EPA 200.8	188644		
70154911045	WATERFOUNTAIN ACROSS 162	EPA 200.8	188644		
70154911046	GIRLS BATHROOM BY B02 LEFT	EPA 200.8	188644		
70154911047	#50 WATERFOUNTAIN BY 125 BUBBL	EPA 200.8	188644		
70154911048	#51 WATERFOUNTAIN MAIN LOBBY B	EPA 200.8	188644		
70154911049	#52 WATEROFUNTAIN BY B02 BUBBL	EPA 200.8	188644		
70154911050	#53 WATEROFUNTAIN BY 162 BUBBL	EPA 200.8	188644		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Intertek - PSI	Report To:	John Tranter	Attention:	
Address:	104 Erie Boulevard Schenectady, NY 12305	Copy To:		Company Name:	
Email:	john.tranter@intertek.com	Purchase Order #:		Address:	
Phone:	518-377-9841	Project Name:	Menards CSD	Pace Quote:	
Requested Due Date:		Project #:	08214093	Pace Project Manager:	nicolette.lovati@pacelabs.com
				Pace Profile #:	0
				Regulatory Agency:	
				State / Location:	NY

ITEM #	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	COLLECTED				SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test	Y/N																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								</
--------	--	---	-----------	--	--	--	-----------------------------	---------------------------------------	---------------------------	-----------------	---------------	--	--	--	--	--	--	---------------	-----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS	
Nicolette Cook			11/24/20	8:45am		11/24/20	8:45	Received on	TEMP in C
Pace			11/24/20	1600		11/24/20	1600	Ice (Y/N)	
								Sealed (Y/N)	
								Custody (Y/N)	
								Cooler (Y/N)	
								Samples Inlet (Y/N)	

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Gifford

SIGNATURE OF SAMPLER:

DATE Signed: 11/21/2020

WO#: 70154911

CHAIN-OF-CUSTODY PM: NML Due Date: 12/11/20
The Chain-of-Custody is a CLIENT: INTERTEKLEAD



Page: 3 Of 5

Section A Required Client Information: Section B Required Project Information: Section C Invoice Info:

Company:	Intertek-PSI	Report To:	John Tranter	Attention:	
Address:	104 Erie Boulevard	Copy To:		Company Name:	
Schenectady, NY 12305				Address:	
Email:	john.tranter@intertek.com	Purchase Order #:		Pace Quote:	
Phone:	518-377-9841	Project Name:	Menands CSD	Pace Project Manager:	nicole.lovat@pacelabs.com,
Requested Due Date:		Project #:	08214093	Pace Profile #:	0

ITEM #	MATRIX	CODE	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample IDs must be unique	SAMPLE TYPE (G=GRAB C=COMP)		COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test	Y/N	Requested Analysis Filtered (Y/N)										Residual Chlorine (Y/N)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
				MATRIX CODE (see valid codes to left)	DATE	TIME	DATE	TIME	START			END	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol			Other																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
25	Boys Bathroom by Main Lobby Left	45		WT	11/21	09:22																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												</

ITEM #	ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME		SAMPLE CONDITIONS	
		Signature	Print Name	Signature	Print Name	Signature	Print Name	Signature	Print Name	Signature	Print Name	Signature	Print Name	Signature	Print Name
		Nicole Conic	Nicole Conic	11/24/20	8:47am					11/24/20	6:47				
				11/24/20	14:00					11/25/20	10:50				

SAMPLER NAME AND SIGNATURE		TEMP in C	Received on	Custody	Sealed	Cooler	Samples
PRINT Name of SAMPLER: James G. Ford							
SIGNATURE of SAMPLER: James G. Ford							
DATE Signed: 11/24/2020							



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A

Required Client Information:

Company: Intertek- PSI
Address: 104 Erie Boulevard
Schenectady, NY 12305
Email: john.tranter@intertek.com
Phone: 518-377-9841 Fax:
Requested Due Date:

Section B

Required Project Information:

Report To: John Tranter
Copy To:
Purchase Order #:
Project Name: Menands CSD
Project #: 08214093

Section C

Invoice Information:




Attention:
Company Name:
Address:
Pace Quote:
Pace Project Manager: nicollette.livari@pacelabs.com,
Pace Profile #: 0

Section D

Regulatory Agency

State / Location
NY

ITEM #	MATRIX Drinking Water Waters Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test	Y/N	Residual Chlorine (Y/N)		
				START	END			H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other					
																		DATE	TIME
37	Girls Bathroom by 125 right	40	WT	11/21	10:31													X	
38	Girls Bathroom by 125 middle	39	WT	11/21	10:19													X	
39	Girls Bathroom by 125 left	38	WT	11/21	10:17													X	
40	Waterfountain by 125	26	WT	11/21	10:33													X	
41	Waterfountain Main Lobby	43	WT	11/21	10:35													X	
42	Boys Bathroom by B02 left	21	WT	11/21	10:46													X	
43	Boys Bathroom by B02 right	20	WT	11/21	10:57													X	
44	waterfountain by B02	14	WT	11/21	10:53													X	
45	waterfountain across 162	16	WT	11/21	11:04													X	
46	Girls Bathroom by B02 Right	23	WT	11/21	N/A													X	
47	Girls Bathroom by B02 Left	22	WT	11/21	10:50													X	

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE	TIME	ACCEPTED BY / AFFILIATION		DATE	TIME	SAMPLE CONDITIONS			
		Nicole Cook		11/24/21	8:41 AM			11/24/20	8:43				
				11/24/20	11:00			11/25/20	10:50	19.1	N	Y	Y



Sample Condition Upon Receipt

WO#: 70154911

Client Name:

Intertek PSI

Project:

PM: NML

Due Date: 12/11/20

CLIENT: INTERTEKLEAD

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 9099 9901 1606

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☒ Yes ☐ NoPacking Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other

Thermometer Used: TH091

Correction Factor: -0.2

Cooler Temperature(°C): 19.7

Cooler Temperature Corrected(°C): 19.5

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)Temperature Blank Present: ☐ Yes ☒ No

Type of Ice: Wet Blue None

☐ Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: 1/11/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

Did samples originate from a foreign source

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ Noincluding Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: SL (WT) OIL		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # H6901495		Sample #
All containers needing preservation are found to be in compliance with method recommendation?		
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		
Per Method, VOA pH is checked after analysis		Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #		
Residual chlorine strips Lot #		Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: